


**PROTECTING OUR WATER SUPPLY AT THE WATERSHED LEVEL
WHAT CITY RESIDENTS CAN DO!**

By all regulatory standards, Canandaigua Lake is a high quality source of drinking water. This is not by chance. Although we have significant natural features that help to provide for a quality water supply such as significant forests and a deep lake; there are still numerous potential pollution threats within the watershed area that need to be actively managed and monitored.

Residents in the City of Canandaigua- specifically areas that drain to Sucker Brook (about 2/3 of the City) and all around the lake can contribute pollution to the lake especially during storm events if we are not careful. Since rain that lands in these areas eventually drains to Canandaigua Lake and ultimately your faucet; human activities occurring within the watershed directly influence the quality of water you drink. The cleaner the water in the lake is: the safer, easier and less expensive it is to treat. Below are some helpful tips to reduce your potential impact on the lake.

- Check your car for leaks and clean up spilled fluids with an absorbent material like kitty litter. Never wash a spill or dump liquids into a nearby storm drain. If you don't clean it - the next storm will wash the spill into the Lake or Outlet.
- Pick up pet waste and dispose it in the trash - pet waste can harbor millions of bacteria.
- Limit the use of lawn fertilizers and pesticides. If you choose to use pesticides or hire a lawn care company that uses pesticides consider following the City's Turf and Landscape Policy (www.canandaiguanewyork.gov) that reduces the use of pesticides by using the following practices:
 - Mowing height of 3-3.5 inches, aeration, overseeding, watering, soil testing for proper fertilizing.
 - Monitor for specific pests and tolerate some level of weeds and pests before pesticides are used. Choose the least toxic pesticide and spot treat with a spray application on problem areas only.
- Using these approaches, the City limits pesticide use on lawn areas to once every 5 years on average as opposed to some lawn care companies standard practice of applying pesticides 4 times a year. Challenge your household or lawn care company to follow these practices to limit the use of pesticides.
- Make sure your watercraft is clean, all the bilge areas are drained and free of any vegetation before launching into Canandaigua Lake. Invasive species can cause major impacts to the lake.
- Build rain gardens on your property and/or use rain barrels to store and filter stormwater runoff.
- Wash your car on your lawn to let the ground absorb the cleaning products or bring it to a commercial car wash.
- Keep a natural buffer along a drainage path on your property. Don't throw leaves or lawn clippings into a stream or storm drain - they have high levels of phosphorus when they decompose.
- Contact the Watershed Council for more information (585 396-3630) or www.canandaigualake.org. Consider supporting our citizen organizations such as The Canandaigua Lake Watershed Association and the Finger Lakes Land Trust which are very active in education and land protection efforts.



Water Treatment Facility

Fed. ID #3401150

2021 Water Quality Report



THE U.S. EPA OFFICE OF WATER www.epa.gov/watrhome and the Centers for Disease Control and Prevention www.cdc.gov websites provide information on many issues related to water resources, water conservation, and public health. The Department of Health's website www.health.ny.gov provides complete and current information on water issues in our own state, including valuable information about our watershed.

INFORMATION ON THE INTERNET

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: inorganic chemical contaminants; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

SUBSTANCES EXPECTED IN DRINKING WATER

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: inorganic chemical contaminants; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

GOT QUESTIONS?
Call U.S. EPA's Safe Drinking Water Hotline at 1-800-426-4791

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at an optimal concentration of 0.7 mg/L (parts per million). To ensure that the fluoride supplement in your water provides optimal dental protection, the State Department of Health requires that we monitor fluoride levels on a daily basis. Our system's average fluoride concentration was 0.79 mg/L. None of the monitoring results showed fluoride at levels that exceeded the 2.2 mg/L MCL for fluoride.

INFORMATION ON FLUORIDE ADDITION

On average, the hardness of the water delivered to your residence or place of business is 130 mg/L (parts per million) or 7.5 grains.

HOW HARD IS MY WATER?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immunocompromised persons such as those with cancer who are undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

SPECIAL HEALTH INFORMATION

Over the years, we have dedicated ourselves to producing drinking water that meets or exceeds all state and federal drinking water standards. We accomplish this by continually striving to adopt new and better methods of delivering the best quality drinking water that we can. As regulations and drinking water standards change, it is our commitment to quickly incorporate these changes system wide in an expeditious and cost effective manner. If you have any health concerns relating to the information in this report, we encourage you to contact your health care provider. For more information about this report, or for any questions relating to your drinking water, please call Peter Vitkier, Chief Operator, at 585-396-5064.

Over the years, we have dedicated ourselves to producing drinking water that meets or exceeds all state and federal drinking water standards. We accomplish this by continually striving to adopt new and better methods of delivering the best quality drinking water that we can. As regulations and drinking water standards change, it is our commitment to quickly incorporate these changes system wide in an expeditious and cost effective manner. If you have any health concerns relating to the information in this report, we encourage you to contact your health care provider. For more information about this report, or for any questions relating to your drinking water, please call Peter Vitkier, Chief Operator, at 585-396-5064.

Once again we are pleased to present to you our annual water quality report. We are proud to report that our system met all New York State standards in 2021. Our system did not violate a maximum contaminant level or any monitoring requirements.

OUR MARK OF EXCELLENCE

Canandaigua Water Plant 2021 Water Quality Report

WHAT'S IN MY WATER?

In accordance with State regulations, the City of Canandaigua routinely monitors your drinking water for numerous contaminants. We test your drinking water for coliform bacteria, turbidity, inorganic contaminants, lead, copper, nitrate, volatile organic contaminants, total trihalomethanes and synthetic organic contaminants. The table presented below depicts which contaminants were detected in your drinking water. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Therefore some of the data, though representative of the water quality, is more than one year old.

REGULATED SUBSTANCES

SUBSTANCE (UNITS)	DATE SAMPLED	MCL	MCLG	AVG AMT.	RANGE (LOW HIGH)	VIOLATION	TYPICAL SOURCE
Barium (ppm)	2/21	2	2	0.024	N/A	No	Discharge of drilling wastes, metal refineries; erosion of natural deposits
Nickel (ppb)	2/21	100	100	1.4	N/A	No	Erosion of natural deposits; discharge from stainless steel factories
Fluoride (ppm) ¹	2021	2.2	N/A	0.79	0.61 - 1.50	No	Erosion of natural deposits; water additive; discharge from aluminum and fertilizer factories
Nitrate (ppm)	2/21	10	10	0.33	N/A	No	Runoff from fertilizer use; leaching from septic tanks; erosion of natural deposits
Chromium (ppb)	2/21	100	100	1.4	N/A	No	Erosion of natural deposits; discharge from stainless steel factories
Total Coliform + E. Coli ⁵	2021	>5% pos.	0	N/A	0	No	Naturally present in the environment
Turbidity Combine Filter Effluent (NTU) ²	2021	TT = 0.3	N/A	0.03 max	0.03 - 0.25	No	Soil runoff
Turbidity Individual Filter (NTU)	2021	TT = 0.3	N/A	99% ≤ 0.3	N/A	No	Soil runoff
Alkalinity (ppm)	2021	N/A	N/A	112	100 - 119	No	Naturally present in the environment
Total Organic Carbon (ppm)	2021	N/A	N/A	2.15	1.8 - 2.4	No	Naturally present in the environment, measured at Entry Point
Dissolved Organic Carbon (ppm)	2021	N/A	N/A	0.026	0.0221 - 0.0325	No	Naturally present in the environment, measured at Raw Water Tap
UV254 (cm ⁻¹)	2021	N/A	N/A	0.0245	0.0203 - 0.0315	No	
Specific Ultraviolet Absorbance (L/mg-m)	2021	N/A	2	1.24	0.98 - 1.6	No	
Raw Water Microcystin (ppb)	2021	N/A	N/A	<0.3	<0.3-0.97	No	Cyanobacteria
Perfluorooctanesulfonic acid (ng/L)	2020	10	N/A	<1.7	N/A	No	Fire fighting foam, water repellent, industrial processes
Perfluorooctanoic acid (ng/L)	2020	10	N/A	<1.7	N/A	No	Fire fighting foam, water repellent, industrial processes
1,4-Dioxane (ppb)	2020	1	N/A	<0.04	N/A	No	

STAGE II							
Total Haloacetic Acids (ppb)	2021	60	N/A	24 ⁶	6 - 30	No	By products of drinking water chlorination
Total Trihalomethanes (ppb)	2021	80	N/A	66 ⁶	41 - 83	No	By products of drinking water chlorination

RADIOLOGICAL							
Gross Alpha (pCi/L)	12/13	15	0	ND	N/A	No	Erosion of natural deposits
Radium 226 (pCi/L)	2/13	5	0	ND	N/A	No	Erosion of natural deposits
Radium 228 (pCi/L)	2/13	5	0	0.4	0.4	No	Erosion of natural deposits

LEAD & COPPER

SUBSTANCE (UNITS)	DATE SAMPLED	AL	MCLG	90TH PERCENTILE	RANGE (LOW HIGH)	VIOLATION	TYPICAL SOURCE
Copper (ppm)	6/20	1.3	N/A	0.028	0.0027 - 0.030	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	6/20	15	N/A	1.0 ³	<1 - 10	0 ⁴ - No	Corrosion of household plumbing systems; Erosion of natural deposits

¹ FLUORIDE IS ADDED TO THE WATER SUPPLY TO HELP PROMOTE STRONG TEETH. THE DEPARTMENT OF PUBLIC HEALTH RECOMMENDS AN OPTIMAL FLUORIDE CONCENTRATION RANGE OF 0.7 PPM TO 1.2 PPM. MEASURED ON LABORATORY'S FINISHED WATER.
² TURBIDITY IS A MEASURE OF THE CLOUDINESS OF THE WATER, AND IS MONITORED AS AN INDICATOR OF THE EFFECTIVENESS OF OUR FILTRATION SYSTEM. THE TURBIDITY RULE REQUIRES THAT 95% OR MORE OF MONTHLY SAMPLES BE BELOW 0.3 NTUS. MEASURED IN LAB.
³ THE LEVEL PRESENTED REPRESENTS THE 90TH PERCENTILE. A PERCENTILE IS A VALUE ON A SCALE OF 100 THAT INDICATES THE PERCENT OF A DISTRIBUTION THAT IS EQUAL TO OR BELOW IT. THE 90TH PERCENTILE IS EQUAL TO OR GREATER THAN 90% OF THE LEAD AND COPPER VALUES DETECTED AT YOUR WATER SYSTEM.
⁴ NUMBER OF HOMES OUT OF 30 THAT WERE ABOVE THE ACTION LEVEL.
⁵ COLIFORMS ARE BACTERIA THAT ARE NATURALLY PRESENT IN THE ENVIRONMENT AND ARE USED AS AN INDICATOR THAT OTHER, POTENTIALLY HARMFUL BACTERIA MAY BE PRESENT.
⁶ THIS LEVEL REPRESENTS THE HIGHEST LOCATIONAL RUNNING ANNUAL AVERAGE CALCULATED FROM DATA COLLECTED.

LEAD: INFANTS AND YOUNG CHILDREN ARE TYPICALLY MORE VULNERABLE TO LEAD IN DRINKING WATER THAN THE GENERAL POPULATION. IT IS POSSIBLE THAT LEAD LEVELS AT YOUR HOME MAY BE HIGHER THAN AT OTHER HOMES IN THE COMMUNITY AS A RESULT OF MATERIALS USED IN YOUR HOME'S PLUMBING. IF YOU ARE CONCERNED ABOUT ELEVATED LEAD LEVELS IN YOUR HOME'S WATER, YOU MAY WISH TO HAVE YOUR WATER TESTED AND FLUSH YOUR TAP FOR 30 SECONDS TO 2 MINUTES BEFORE USING YOUR TAP WATER. ADDITIONAL INFORMATION IS AVAILABLE FROM THE SAFE DRINKING WATER HOTLINE (800-426-4791).

TABLE DEFINITIONS

Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Amount Detected: This column represents an average of sample result data collected during the reporting year. In some cases, it may represent a single sample if only one sample was collected.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as possible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

N/A: Not applicable

ND: Not detectable at testing limits.

Nephelometric Turbidity Units (NTU): Measure of the clarity, or turbidity, of water.

Parts per Billion: One part of liquid in one billion parts of liquid (or microgram per liter).

Parts per Million: One part of liquid in one million parts of liquid (or milligram per liter).

Range (Low - High): This column represents a range of individual sample results, from lowest to highest, that were collected during the reporting year.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Picocuries per Liter (pCi/L): Picocuries per liter is a measure of radioactivity in water.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

WHERE DOES MY WATER COME FROM?

The Canandaigua Water Treatment Plant draws water from Canandaigua Lake as its sole source. In 2021, the Facility withdrew 1.443 billion gallons of water from the lake and produced 1.374 billion gallons of water for distribution. The balance was used for backwashing and internally within the water plant. Of the distribution amount, approximately 349 million gallons were metered and sold to the 11,000 residents of the City of Canandaigua at a cost of \$3.52/1000 gallons. The City also sold and metered 969 million gallons of water to the Towns of Canandaigua, Farmington, and Hopewell. This leaves a total of 45 million gallons or 3.3% of water produced which was lost. This is the amount of water used for firefighting purposes, hydrant flushing, distribution leaks and old, inaccurate meters yet to be replaced.

HOW IS MY WATER TREATED AND PURIFIED?

Canandaigua Lake water is drawn into the plant through an intake pipe. Chlorine is added at the intake to prevent zebra & quagga mussels from colonizing the interior of the pipe and also to control the growth of bacteria and algae.

The lake water is then pumped up to the rapid mix chamber in the process building. Here a coagulant, polyaluminum chloride, is added. This starts the process of coagulation where the coagulant comes into contact with any particles in the water for eventual removal by settling. Powdered activated carbon can be added at this point to control taste and odor issues within the water. The water then goes into a series of basins for a process known as flocculation. This process of gentle agitation causes particles present in the water to agglomerate and form larger and heavier particles known as floc.

By the time the water moves into the settling basins, the formed floc is heavy enough to settle out to the bottom of the tank for removal. The settled waste is periodically drawn off to a holding tank and eventually discarded. After the settling basins, the water is directed to the rapid sand filters. A mixed media filtration system consisting of anthracite coal, sand and garnet filter out any remaining particles.

After water has passed through the filters a final dose of disinfecting chlorine is added. Also added are sodium hydroxide, to balance the pH and prevent corrosion in the distribution system, and a measured quantity of fluoride.

To ensure excellent water quality, water samples are taken regularly and at various stages of the treatment process. These samples are tested for various water quality parameters in New York State certified laboratories. Routine tests are also performed on samples taken in the distribution system on a regular basis.

SOURCE WATER ASSESSMENT

New York State has completed the Source Water Assessment for Canandaigua Lake and found a moderate susceptibility to contamination for this source of drinking water. The amount of agricultural lands in the assessment area results in elevated potential for protozoa, phosphorus, DBP precursors, and pesticides contamination. While there are some facilities present, permitted discharges do not likely represent an important threat to source water quality based on their density in the assessment area. However, it appears that the total amount of wastewater discharged to surface water in this assessment area is high enough to further raise the potential for contamination (particularly for protozoa). There is also noteworthy contamination susceptibility associated with other discrete contaminant sources, and these facility types include: hazardous waste sites, chemical bulk storage, landfills, mines, RCRA and TRI.

Further information on the source water assessment of our community water supply is available on the U.S. Geological Survey (USGS) website at ny.water.usgs.gov.

WATER CONSERVATION TIPS

Conservation is an important first step in preserving our water supply. Using these measures can also save you money by reducing your water and sewer bills. Here are a few suggestions.

Conservation measures you can use inside your home:

- Fix leaking faucets, pipes and toilets.
- Install water saving devices in faucets, toilets and appliances
- Replace high water use fixtures.
- Wash only full loads of laundry.
- Do not use the toilet for trash disposal.
- Take shorter showers.
- Do not let the water run while shaving or brushing teeth.
- Run the dishwasher only when full.

YOU CAN CONSERVE OUTDOORS AS WELL:

- Water the lawn and garden in the early morning or evening.
- Use mulch around plants and shrubs.
- Repair leaks in faucets and hoses.
- Use water saving nozzles and sprinkler heads.
- Use water from a bucket to wash your car and save the hose for rinsing.

COMMUNITY PARTICIPATION

You are invited to participate in our public forum and voice your concerns about your drinking water. The City Council meets the first Thursday of each month at 2 North Main Street, Canandaigua. Council meetings begin at 7:00 pm.

GOT QUESTIONS?

Call New York State Dept. of Health:
Geneva District Office: 315-789-3030